

CERTIFICATE OF COMPLIANCE

Certificate Number 20190305-EX9182
Report Reference EX9182-20080515
Issue Date 2019-MARCH-05

Issued to: NanJing Fire Protection Technology Co Ltd
No.599 Zhushan Road, Jiangning District, Nanjing
Jiangsu 211112 CHINA

**This certificate confirms that
representative samples of**

VALVES, ALARM

Alarm valves and accessories, Model NX009, 4 and 6 inch
sizes rated at 175 psig, Model NX010 water motor gong,
maximum pressure 175 psi.

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.


Standard(s) for Safety: UL 193 - Alarm Valves for Fire-Protection Service
UL 753 - Alarm Accessories for Automatic Water-Supply
Control Valves for Fire Protection Service

Additional Information: See the UL Online Certifications Directory at
<https://iq.ulprospector.com> for additional information.

This *Certificate of Compliance* does not provide authorization to apply the UL Mark. Only the UL Follow-Up
Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's
Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

