



Certificate of Compliance

This certificate is issued for the following equipment:

Automatic Sprinklers for Fire Protection

Model	K	Type	Resp.	Element	NPT (in.) or R	Finishes	Temperature Ratings °F (°C)
NX021	5.6	Horizontal Sidewall	SR	Job G5 5mm	1/2	Brass, Chrome	135, 155, 200 (57, 68, 93)
NX022	5.6	Horizontal Sidewall	QR	Job F3 3mm	1/2	Brass, Chrome	135, 155, 175, 200 (57, 68, 79, 93)

Prepared for: Nanjing Fire Protection Technology Co., Ltd., No. 599 Zhushan Road, Jiangning District, Nanjing, China

Manufacturing Location: Nanjing Fire Protection Technology Co., Ltd., No. 599 Zhushan Road, Jiangning District, Nanjing, China

FM Approvals Class: 2012

FM Approval Standard: Class Series 2000 (February 2018)

Approval Identification: 3053441

Approval Granted: November 4, 2020

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.



Member of the FM Global Group

A handwritten signature in dark ink, appearing to read "David B. Fuller".

David B. Fuller
VP, Manager – Fire Protection
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062
USA



Certificate of Compliance

This certificate is issued for the following equipment:

Automatic Sprinklers for Fire Protection

Model	K	Type	Resp.	Element	NPT (in.) or R	Finishes	Temperature Ratings °F (°C)
NX023	5.6	Upright	SR	Job G5 5mm	1/2	Brass, Chrome	135, 155, 200 (57, 68, 93)
NX024	5.6	Upright	QR	Job F3 3mm	1/2	Brass, Chrome	135, 155, 175, 200 (57, 68, 79, 93)

Prepared for: Nanjing Fire Protection Technology Co., Ltd., No. 599 Zhushan Road, Jiangning District, Nanjing, China

Manufacturing Location: Nanjing Fire Protection Technology Co., Ltd., No. 599 Zhushan Road, Jiangning District, Nanjing, China

FM Approvals Class: 2016
FM Approval Standard: Class Series 2000 (February 2018)

Approval Identification: 3053441

Approval Granted: November 4, 2020

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.



Member of the FM Global Group

A handwritten signature in dark ink, appearing to read "D.B. Fuller".

David B. Fuller
VP, Manager – Fire Protection
FM Approvals
1151 Boston-Providence Turnpike



Certificate of Compliance

This certificate is issued for the following equipment:

Automatic Control Mode Sprinklers for Fire Protection

Model	K	Type	Resp.	Element	NPT (in.) or R	Finishes	Temperature Ratings °F (°C)
NX025	5.6	Pendent	SR	Job G5 5mm	1/2	Brass, Chrome	135, 155, 200 (57, 68, 93)
NX026	5.6	Pendent	QR	Job F3 3mm	1/2	Brass, Chrome	135, 155, 175, 200 (57, 68, 79, 93)

Prepared for: Nanjing Fire Protection Technology Co., Ltd., No. 599 Zhushan Road, Jiangning District, Nanjing, China

Manufacturing Location: Nanjing Fire Protection Technology Co., Ltd., No. 599 Zhushan Road, Jiangning District, Nanjing, China

FM Approvals Class: 2016

FM Approval Standard: Class Series 2000 (February 2018)

Approval Identification: 3053441

Approval Granted: November 4, 2020

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.



Member of the FM Global Group

A handwritten signature in dark red ink, appearing to read 'J. B. Fuller', is located at the bottom center of the page.



Certificate of Compliance

David B. Fuller
VP, Manager – Fire Protection
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062
USA



Member of the FM Global Group



Certificate of Compliance

This certificate is issued for the following equipment:

Automatic Sprinklers for Fire Protection

Model	K	Type	Resp.	Element	NPT (in.)	Finishes	Temperature Ratings °F (°C)
NX021	5.6	Horizontal Sidewall	SR	Job G5 5mm	1/2	Brass, Chrome	175 (79)
NX023	5.6	Upright	SR	Job G5 5mm	1/2	Brass, Chrome	175 (79)
NX025	5.6	Pendent	SR	Job G5 5mm	1/2	Brass, Chrome	175 (79)

Prepared for:

Nanjing Fire Protection Technology Co., Ltd.
No. 599 Zhushan Road, Jiangning District, Nanjing, China

Manufacturing Location:

Nanjing Fire Protection Technology Co., Ltd.
No. 599 Zhushan Road, Jiangning District, Nanjing, China

FM Approvals Class: 2012, 2016, 2017

FM Approval Standard: Class Series 2000 (February 2018)

Approval Identification: PR459338

Approval Granted: May 28, 2021

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.



Member of the FM Global Group

A handwritten signature in dark ink, appearing to read 'D. B. Fuller', is written over a horizontal line.

David B. Fuller
VP, Manager – Fire Protection
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062
USA