

## Certificate of Compliance

This certificate is issued for the following equipment:

### Automatic Sprinklers for Fire Protection

| Model | K   | Type    | Resp. | Element    | NPT (in.) | Finishes  | Temperature Ratings °F (°C)         |
|-------|-----|---------|-------|------------|-----------|-----------|-------------------------------------|
| NX023 | 5.6 | Upright | SR    | Job G5 5mm | 1/2       | Polyester | 135, 155, 175, 200 (57, 68, 79, 93) |
| NX024 | 5.6 | Upright | QR    | Job F3 3mm | 1/2       | Polyester | 135, 155, 175, 200 (57, 68, 79, 93) |
| NX025 | 5.6 | Pendent | SR    | Job G5 5mm | 1/2       | Polyester | 135, 155, 175, 200 (57, 68, 79, 93) |
| NX026 | 5.6 | Pendent | QR    | Job F3 3mm | 1/2       | Polyester | 135, 155, 175, 200 (57, 68, 79, 93) |

Prepared for:

Nanjing Fire Protection Technology Co., Ltd.  
No. 599 Zhushan Road, Jiangning District, Nanjing, China

Manufacturing Location:

Nanjing Fire Protection Technology Co., Ltd.  
No. 599 Zhushan Road, Jiangning District, Nanjing, China

FM Approvals Class: 2016, 2017

FM Approval Standard: Class Number 2000 (November 2024)

Approval Identification: PR470732

Approval Granted: 28 January 2026

To verify the availability of the Approved product, please refer to [www.approvalguide.com](http://www.approvalguide.com)

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.



A handwritten signature in black ink, appearing to read 'D.B. Fuller'.

David B. Fuller  
VP, Manager – Fire Protection  
FM Approvals  
One Technology Way  
Norwood, MA 02062 USA

